ANNEX M

VICTORIAS CITY WATER DISTRICT
Quirino St. Brgy. 5, Victorias City, Negros Occidental

2015 SUMMARY OF BACTERIOLOGICAL ANALYSIS

Particulars	Jan-2015	Feb-2015	Mar-2015	Apr-2015	May-2015	Jun-2015	Jul-2015	Aug-2015	Sep-2015	Oct-2015	Nov-2015	Dec-2015
1. Minimum Required Samples per month	6	6	6	6	6	6	6	6	6	6	6	6
Number of Samples Examined for the Month	9	7	10	10	9	10	6	6	6	9	10	10
Meet requirements of PNSDW	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
2. Total Coliform												
MTFT - No. of Samples with Total Coliform Values<1.1 MPN/100ml	9	7	10	10	9	10	6	6	6	9	10	10
Meet Standard	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
3. Fecal Coliform												
MTFT - No. of Samples with Total Fecal Coliform Values<1.1 MPN/100ml	9	7	10	10	9	10	6	6	6	9	10	10
Meet Standard	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
4. Heterotrophic Plate Count (HPC)												
Number of HPC test conducted	9	7	10	10	9	10	6	6	6	9	10	10
Number of samples showing HPC values<500CFU/ml	9	7	10	10	9	10	6	6	6	9	10	10
Meet PC Standard Results	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
OVERALL EVALUATION	Passed	Passed	Passed	Passed	Passed	Passed	Passed	Passed	Passed	Passed	Passed	Passed