



REPUBLIC OF THE PHILIPPINES  
**VICTORIAS CITY WATER DISTRICT**

Quirino St., Victorias City Negros Occidental  
Telefax: (034) 399-3554, Tel. No. (034) 399-2865  
Website: victoriacitywd.gov.ph  
Email: victoriacitywd@yahoo.com.ph

---

**Supplemental Bid Bulletin No. 1**  
**PhilGEPS Bid Reference No. 5980478**  
January 29, 2019

**TO ALL PROSPECTIVE BIDDERS:**

This addendum is a result of the request by the BAC Technical Working Group (TWG) to clearly specify the Technical Specification of the Motor. This shall modify or amend some provisions in the Bidding Documents for *Supply & Delivery of Submersible Pump and Motor*.

This shall form an integral part of the Bid Documents.

---

Invitation to Bid for **SUPPLY & DELIVERY OF SUBMERSIBLE PUMP AND MOTOR.**

**ADDENDUM NO. 1**

REFERENCE			AMENDMENTS/CHANGES/CLARIFICATION		
Technical Specifications			Technical Specifications		
Item	Specification	Statement of Compliance	Item	Specification	Statement of Compliance
		Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence.			Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence.
<b>1</b>	<b>Submersible Pump</b>		<b>1</b>	<b>Submersible Pump</b>	
	Rated flow: 92 m <sup>3</sup> /hr			Rated flow: 92 m <sup>3</sup> /hr	
	Rated head: 69 m			Rated head: 69 m	
	Standard: ISO 9906:2012 3B			Standard: ISO 9906:2012 3B	
	Pump Material: stainless steel AISI 304			Pump Material: stainless steel AISI 304	
	Impeller Material: stainless				

	steel AISI 304	
<b>2</b>	<b>MOTOR</b>	
	Material: stainless steel AISI 304	
	Pump outlet: 5" NPT	
	Motor diameter: 6 inch	
	Rated power: 22kW (30HP)	
	Mains Frequency: 60Hz	
	Rated voltage: 3 x 380-400 V	
	Service Factor: 1.15	
	Rated Current: 56.0-55.0 A	
	Rated Speed: 3470-3480 rpm	
	Enclose class: IP68	
<b>3</b>	<b>Product Brochure/Catalogue</b>	
<b>4</b>	<b>1 year Warranty</b>	

I hereby certify to comply with all the above Technical Specifications.

\_\_\_\_\_  
Name of Company/ Bidder  
Date

\_\_\_\_\_  
Signature over Printed Name

	Impeller Material: stainless steel AISI 304	
<b>2</b>	<b>MOTOR</b>	
	Material: stainless steel AISI 304	
	Pump outlet: 5" NPT	
	Motor diameter: 6 inch	
	Rated power: 22kW (30HP)	
	Mains Frequency: 60Hz	
	<b>Rated voltage: 3 x 440 V</b>	
	Service Factor: 1.15	
	<b>Rated Current: 48.0 A</b>	
	<b>Rated Speed: 3450rpm</b>	
	Enclose class: IP68	
<b>3</b>	<b>Product Brochure/Catalogue</b>	
<b>4</b>	<b>1 year Warranty</b>	

I hereby certify to comply with all the above Technical Specifications.

\_\_\_\_\_  
Name of Company/ Bidder  
Date

\_\_\_\_\_  
Signature over Printed Name

For the guidance and information of all concerned.

  
LINO T. BASCUG

Chairperson, Bids and Awards Committee